



# APRAGAZ

a.s.b.l.  
Your Inspection Authority



Chaussée de Vilvorde, 156 B-1120 Brussels  
Phone 32/2/264 03 60 - Fax. 32/2/268 89 58  
e-mail : info@apragaz.com - V.A.T. BE 407.199.070

SAE S.r.l.  
Corso Kennedy, 30  
IT - 10070 ROBASSOMERO (TORINO)

Y/Ref. :  
O/Ref. : CHL/MMO

June 2, 2016

## APPROVAL CERTIFICATE EN 3-7 – PORTABLE FIRE EXTINGUISHERS FOR BUILDINGS *extension of the approval for modification of constructive detail and other fire rating*

We hereby declare that the hereafter mentioned extinguishers were type approved according to the requirements of the EN 3-7 standards, according to the tests reports and with the hereafter mentioned approval number:

Approval No.	Brand	Type	Nominal charge	Fire ratings achieved	EN 3-7 test report No.
EN3-16/384-1	SAE	6D-58-A	6 l water + add. (5,91 l SAE-Aplus + 90 ml BSX233)	43 A - 75 F	EN 11635-1
EN3-16/385-1	SAE	9D-58-A	9 l water + add. (8,91 l SAE-Aplus + 90 ml BSX233)	55 A - 75 F	EN 11636-1

The approval is subject to the continued maintenance of the Quality System of the manufacturer in accordance with the relevant requirements of EN 3-10.

The manufacturer is authorized to affix the above mentioned approval number on the marking label of the approved corresponding extinguishers as long as the results of our inspections, periodically made according to the requirements of § 10 of the EN 3-10, are satisfactory.

Nota Bene: additional requirements (i.e. language of the labels, maintenance requirements, ...) may be made by national regulations and/or quality marks.

The General Manager,

Christian LEPLAT, ir.